

City of Havelock
Westbrooke Pump Station, Discharge Pipe Leak Repair
Addendum 4
April 6, 2017

On cover page replace "Bids will be accepted until **3:00 p.m. (EST) on Wednesday, April 5, 2017** at which time they will be reviewed in the office of the City Finance Director" with "Bids will be accepted until **3:00 p.m. (EST) on Wednesday, April 12, 2017** at which time they will be reviewed in the office of the City Finance Director."

The following questions were received:

1. Addendum #3 requests new base elbows for the pump station. The base elbows must match the pumps, which means we must know the manufacturer and model number of the pumps to obtain the correct sealing connection to each other.
2. The base ells will also have the brackets that will support the guide rails from the bottom of the wet well, since the addendum requests new guide rails.

Answer:

1. Information concerning the two existing pumps is provided below:

Manufacturer	Model	Ser Number	FLA	HP	Voltage
Hydromatic	S4M1500M3-4	10058893	44.2	15	230
Hydromatic	S4M1200M3-4	12257	27	12	230

2. The new guide rails shall be replaced with the hydrorail style base 90 and guide rail system since these pumps are above 10hp and they have a higher starting torque which is the need for the hydrorail system.

Thank you for your continued interest in our project.

CITY OF HAVELOCK



Lee W. Tillman

Finance Director