

**MARION STREET
REPAIR AND RESURFACING
CITY OF WAYCROSS, GEORGIA
BID NO. FY 22-01**

BIDS DUE August 5, 2021; 2:00 PM Local Time

**ADDENDUM NO. 1
August 2, 2021
12:30 PM**

THE PLANS, SPECIFICATIONS AND BIDDING DOCUMENTS FOR THE PROJECT NAMED ABOVE ARE HEREBY AMENDED AS DESCRIBED ON THE FOLLOWING PAGES. THE BIDDER MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACES PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY RESULT IN REJECTION OF THE BID.

CLARIFICATIONS

The following clarifications are offered in response to questions received in writing:

Question: We would like some clarification on how to handle abandoning the services on the existing 2" and 12" water lines at the main.

Response: This is a full depth pavement reclamation project and the work description found in Section 01270 "Measurement and Payment" on Page 8 of 14 Paragraphs (a) and (b) are applicable. The Existing 2" mains are to be abandoned and the services connected to the existing 12" mains require shutting off and capping or plugging the existing corporation stops. All existing services to be reconnected to the new 4" PVC main in accordance with paragraphs (i) and (j) on page 10 of 14.

SPECIFICATIONS

DIVISION 00

SECTION 00200 – INSTRUCTIONS TO BIDDERS

7.0 SUBMISSION OF BIDS

On Page 3 of 4

Delete the requirement for submission of Section 00415 "Major Subcontractor Listing

END OF ADDENDUM NO. 1