

“City of Havelock
Water Plant Rehabilitation”
Addendum 2
February 1, 2021

Questions Received

1. On page 6, Under Softener Scope. It states that vessel interior rehab includes repair and two coats of Epoxy. Also states welding and pit filling. What about surface preparation? Is the interior to be sandblasted as well?

Softener interior rehab to include the repair of vessel interiors, including sandblasting, painting, welding and pit filling, and surface wash.

2. Also on Page #7, still on softener scope. It speaks on converting the 2" up rinse to 6" Down rinse. Is there clarification for who is providing the AUMA actuator/valve? If so, could we get the actuator specifications needed for this upgrade for accurate pricing?

The Auma actuator/valve is to be provided by the City. The Auma actuator is model number SQR07.2/AC01.1.