

“City of Havelock
Water Plant Rehabilitation”
Addendum 2
February 2, 2021

Questions Received

1. It appears that the plant is such that all of side A can be taken out of service, and the plant can continue production using side B. Can you please confirm that all five (5) vessels (3 filters, 2 softeners) on Side A can be out-of-service at the same time, and vice versa for side B (if both Alternates 1 and 2 are awarded)?

Yes

2. Also, will the contract time of 90 days be extended if either or both of the alternates are awarded?

No

3. Alternate #1 part C says replace exterior pipe for proper down rinse. including the Valve and Actuator. I am assuming that the City is supplying the valves also.

Yes

4. What is the Quantity on the valve and pipe replacement? Is it 3 for the filters since under filter scope? Or two for the softeners, like on side A?

1 per softener for a total of 4.

5. Is the DI 90's, Spools, Pipe, or Zip flanges also provided by the City for the valve upgrades? Or is the City only supplying the valves for sides A&B?

The City is only supplying the valves.

6. Relocation of Air Relief Valves. (what is quantity on this?)

The air relief valves are for side b filters 4, 5, and 6 only.