

Finance Department
 Fifty Raupp Blvd.
 Buffalo Grove, IL 60089-2198
 Phone 847-459-2525
 Fax 847-459-7906

**2019 University Drive Street and Utility Improvement Project
 ADDENDUM #1**

TO: Prospective Bidders and Other Interested Parties

FROM: Village of Buffalo Grove Finance Department

ISSUE DATE: August 2, 2019

SUBJECT: ADDENDUM #1

Note: This Addendum is hereby declared a part of the original proposal documents and in case of conflict, the provisions in the following Addendum shall govern.

The following changes and clarifications shall be made to the Bid Documents for 2019 University Drive Street and Utility Improvement Project.

Revision 1 Local Agency Proposal Bid Bond (Form BLR 12230) – Bond Percentage

The bid bond percentage on the Local Agency Proposal Bid Bond Form BLR 12230 has been revised to 10% of the total bid price to be consistent with the bid bond indicated in the Local Public Agency Formal Contract Proposal (Form BLR 12200), page 4 of 7, in the Contract Front End Documents.

Clarification 1 What are the approximate lengths, sizes, and types of the pipes to be installed on the project?

The lengths, sizes, and types of pipes are included in the Summary of Quantities within the plan set as well as the Contract Documents. The below chart and item number corresponds to the item number in the plans and specification documents

Item No.	Items	Unit	Quantity
49	WATERMAIN, DUCTILE IRON PIPE, CLASS 52, 6" (SPECIAL)	FOOT	121
50	WATERMAIN, DUCTILE IRON PIPE, CLASS 52, 8" (SPECIAL)	FOOT	38
51	WATERMAIN, DUCTILE IRON PIPE, CLASS 52, 10" (SPECIAL)	FOOT	2,322
52	WATERMAIN, DUCTILE IRON PIPE, CLASS 52, 12" (SPECIAL)	FOOT	130
53	WATERMAIN, DUCTILE IRON PIPE, CLASS 52, INSULATED 10" (SPECIAL)	FOOT	50
54	WATER SERVICE, TYPE K COPPER, 1" (SPECIAL)	FOOT	1,302
67	FORCEMAIN, 10" PVC, C900, DR14 (SPECIAL)	FOOT	2,167
71	STORM SEWERS, TYPE 2, WATER MAIN QUALITY PIPE, 12"	FOOT	239
72	STORM SEWERS, TYPE 2, WATER MAIN QUALITY PIPE, 15"	FOOT	53
73	STORM SEWERS, TYPE 2, WATER MAIN QUALITY PIPE, 24"	FOOT	141
74	PIPE UNDERDRAINS 4"	FOOT	860

Clarification 2 Are there any portions of the project that will need to be bored?

The watermain installation must be open cut. The Contractor has the option to open cut or directionally drill the forcemain per the specifications approved by the Village.

Clarification 3 Are the crossings to be Jack and Bored or Directionally Bored?

Per the specification this is at the discretion and option of the Contractor approved by the Village. Per the specification the Contractor has the option to open cut or directionally drill the 10-inch forcemain. The water main must be installed utilizing an open cut method.

Clarification 4 What are the approximate lengths and diameters of the portions to be bored?

The watermain installation must be open cut. The Contractor has the option to open cut or directionally drill the forcemain. The approximate length of directionally drilled forcemain is the option of the contractor. The diameter is the is the 10-inch PVC forcemain.

Clarification 5 How much is the required bid bond for the project?

The bid bond for the project is 10% of the total bid price. The bid bond percentage on the Local Agency Proposal Bid Bond Form BLR 12230 has been revised to 10% of the total bid price to be consistent with the bid bond indicated in the Local Public Agency Formal Contract Proposal (Form BLR 12200), page 4 of 7, in the Contract Front End Documents.

Clarification 6 How much is the cost estimate of the project?

This information is not to be disclosed and cannot be provided during the bidding process.

**PROSPECTIVE BIDDERS ARE TO ACKNOWLEDGE RECEIPT OF ADDENDUM #1.
INCLUDE AND NOTE THIS ADDENDUM IN YOUR PROPOSAL.**

PROSPECTIVE BIDDER: _____

SIGNED: _____ **DATE:** _____