

ADDENDUM NO. 2

**Chattanooga Downtown Library
ADA Bathrooms
City Contract No. L-20-002
Chattanooga, Tennessee**

Date: 31 July 2020

The following amendments to the specifications and/or revisions to the drawings shall be a part of the contract documents. Bidders therefore shall consider them when preparing cost estimates, and the contractors shall be bound by them.

GENERAL

Site Visit

A second site visit is scheduled for Tuesday, August 4, 2020 beginning at 10:30 AM. Contractors and sub-contractors will be escorted individually to the various parts of the building by the architect and library staff employees.

Questions Received and Answers

Q: Are there any plans or specifications for the work being completed?

A: Yes, refer to city purchasing department

Q: Will the site walks for each of these be the only times each space will be able to be accessed?

A: Yes, unless another site walk is issued by addendum. (see note above about new site visit)

Q: I see these are both due 8/13/20 at 2PM. Will each of these be submitted at the same location?

A: This answer applies to this project only. See date and time for bid opening below.

Q: Will bonding be required for this project?

A: Yes

Q: Will this project require a scaled Davis Bacon wage rate?

A: No

Sign-up Sheet

Attached is the sign-up sheet from the pre-bid meeting on July 30, 2020.

SPECIFICATIONS

Section 100100 Advertisement for Bids

Change the date and time for bid opening to Thursday, August 13 at 2:00 PM. Same location.

Add: Final questions will be received no later than Friday, August 7, 2020 at 2:00 PM

DRAWINGS

Sheet A12 Enlarged Floor and Ceiling Plans

Detail A13 – Fourth Floor Enlarged Plan

Relocate two acoustical panels from existing West wall where toilets are located to North wall of Event Space 4-54 (back side of Toilet 4052).

Sheet M1.0 HVAC 1st-3rd Floor

Details 2 HVAC 2nd Floor Plan and 3 HVAC 3rd Floor Plan

Relocate existing electronic thermostats on South wall of each room approximately 8'-0" horizontally to South wall of adjacent alcove.

Sheet E2.0 Lighting Basement – 4th Floor

Detail 2 – Electrical 2nd Floor Lighting

Note that a smoke detector on the ceiling must be relocated 2'-0" North into an existing ceiling tile.

SIGN-IN SHEET

PROJECT: LIBRARY ADA BATHROOMS #30 AM 7/30/20 PREBID

	NAME	COMPANY	PHONE	EMAIL
1	BONNIE MUMFORD DODSON	OC	643 6031	BMUMFORD@CHATTANOOGA.GOV
2	DEBBIE TAUGY	OC	643 7230	DTAUGY@CHATTANOOGA.GOV
3	JASON PAYNE	OC	643 5815	JPAYNE@CHATTANOOGA.GOV
4	JASON SULLIVAN	LIBRARY	643 7715	JSULLIVAN@CHATTANOOGA.GOV
5	KEVIN KEATING	CROWN SERVICE	770.845.4291	WKEATING@CROWNSC.NET
6	BILL WILKERS	DHW ARCH	423.266.4816	bill@dhw-architects.com
7	CRAIG SKIDMORE	L SQUARED	423.509.7882	CRAIG@LSQUARED.BUILD
8	David Lynn	J+J Contractors	423-255-6158	David@jjcontractors.com
9	JON CLINARD	INTEGRATED PROPERTIES	423-643-8448	JCLINARD@INTEGRATEDBUILDS.COM
10	Corinne Hill	Library	940.391.4819	chill@lib.chattanooga.gov
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				