

**PURCHASING
AND MATERIALS
MANAGEMENT**



**City of Myrtle Beach
SOUTH CAROLINA**

**(843) 918-2170
FAX: (843) 918-2182
www.cityofmyrtlebeach.com**

**Addendum 02
December 28, 2022
IFB 23-B0027
City of Myrtle Beach Compactor Upfit**

The purpose of this Addendum 02 to IFB 23-B0027 for City of Myrtle Beach Compactor Upfit, dated December 28, 2022, is to answer the following questions:

1. The drawing shows 6" curb but new bid tab is showing 12" curb. Which would you like?

The total height will be 12"; 6" below ground and 6" above. It was shown on the plan as to be 6" above existing concrete pad.

2. There are 3 existing bollards, would you like these removed?

The bollards can stay since they will fall into the location that will be filled in with the new wall.

3. Will there be an added requirement of curing agent/sealer added to the project?

We will not be including sealer in this project.

Sealed bids are due no later than Wednesday, January 4, 2023 at 1:30PM (local time) at:

City of Myrtle Beach Procurement Office
3231 Mr. Joe White Avenue
Myrtle Beach, SC 29577
Attn: Brandon Hancock