



THE CITY OF DAYTONA BEACH OFFICE OF THE PURCHASING AGENT

Post Office Box 2451
Daytona Beach, Florida 32115-2451

Phone (386) 671-8080
Fax (386) 671-8085

ADDENDUM NO. 1

DATE: October 30, 2018

PROJECT: ITB 19083
WILLIAMSON BLVD. - DUNN AVE TO MASON AVE, RECLAIMED
WATER IMPROVEMENTS

OPENING DATE: NOVEMBER 13, 2018

This addendum is hereby incorporated into the Bid Documents for the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strikethrough~~.

1. Engineer's estimate Order of Magnitude \$1-1.5 million.
2. Answers to Bidders' written questions:

Q1: Concerning Bid Item #2, we would like to request your review and approval of Fusible Polyvinyl Chloride (PVC) pipe as an "equal" or "deductive alternate" to the specified HDPE pipe for the horizontal directional drill sections of this project.

A1: Fusible PVC pipe as a substitute to the specified HDPE *is not approved* as an equal or alternative on this project. PVC pipe is much thinner than HDPE thus has less tolerance for damage during installation.

Q2: The Williamson Blvd-Dunn Ave to Mason Ave Reclaim Water Improvement project bids 11/13 calls for HDPE for the directional bore portion of this project. I am writing today to see if Certa-Lok restrained joint PVC pipe is an acceptable alternative to HDPE for this project. I have been asked by multiple water works distributors to quote Certa-Lok in lieu of HDPE due to the long lead times and availability of this product, especially for large diameter pipe.

A2: Certa-Lok restrained joint PVC pipe *is not approved* as an alternative to HDPE for this project. PVC pipe is much thinner than HDPE thus has less tolerance for damage during installation.

Q3: Since vary large diameter projects (18" and greater) that are available to bid are rare, I would like to request that you reduce the Minimum Qualifications for Utilities Construction by Open Cut to:

"Successful completion of at least five (5) projects for pipe "greater than or equal to 16-inches in diameter using open cut construction."

A3: "The minimum experience for open cut construction *remains as stated* in the bid documents. We will not reducing the required experience."

3. All other terms and conditions remain the same.

The Bidder shall acknowledge receipt of this addendum in Section 7 of the Bid Proposal Form.

The City of Daytona Beach

Joanne Flick
>Purchasing Agent>Buyer

Remember to register with the City of Daytona Beach at www.vendorregistry.com to be notified of bid opportunities with the City. As of 9-30-18 we are no longer using the old system.