



**PURCHASING
AND MATERIALS
MANAGEMENT**

**City of Myrtle Beach
SOUTH CAROLINA**

**(843) 918-2170
FAX: (843) 918-2182
www.cityofmyrtlebeach.com**

Addendum #03

July 19, 2019

**IFB 20-B0002
ADA Door Openers**

The purpose of this Addendum #03 to IFB 20-B0002 for ADA Door Openers, dated July 9, 2019, and previously amended on July 9, 2019 and July 19, 2019, is to answer the following question:

1. The specified height of the post is 50 inches. The standard height of a post is 42 inches. Will the 42-inch post be acceptable, or do we need to order a custom size post?

The post should be no lower than the standard 42-inch height, and no taller than the 50-inch height. These measurements include the overall height from ground to top of cap.

Sealed bids are due no later than Thursday, August 1, 2019 at 2:00PM (local time.)

Thank you,
City of Myrtle Beach
Ann Sowers
Purchasing Office/Buyer
Email: asowers@cityofmyrtlebeach.com