



PURCHASING AND
MATERIALS MANAGEMENT

City of Myrtle Beach
SOUTH CAROLINA

(843) 918-2170
FAX: (843) 918-2182

ADDENDUM 004

March 14, 2018

18-B0113

HVAC Replacement Program


The following question has been asked and answered:

I visited 3 buildings today and had 2 maintenance people on site and did not have any good luck locating units . The city hall had a unit that had been changed and the other 2 could not identify the air handlers . At city services building We had 4 people looking for unit number 5 because the thermostats are not marked. The condensers were the only thing that was available . Fire station #1 you are calling to replace unit 2A there is 2 units there that are close 2c and 2 h . with no matching serial numbers . The humane society has been changed as said in the addendum . I did not visit the Pepper Gedding building but I hear that a unit already has been changed . We will need a better list of locations and or areas . No one at these locations knows where these units are other than the outdoor units. Thermostats are not marked and some condensers are not marked . Can you help with this process so we may put together a quality bid in a timely fashion?

A: It was indicated at the pre-bid that some of the HVAC units may not be marked or their thermostats. It will be the responsibility of the Mechanical Contractor to verify the location and numbers of the units. As in a unit 2A, A stands for Air Handler. It was indicated, that at the end of the project the Mechanical Contractor will have each HVAC Unit marked.

The bid opening date will remain the same, 10:00 March 21, 2018.

Thank you,


Ruth Burleson/Buyer

City of Myrtle Beach