ADDENDUM #3

Jackson County Airport Crack Seal & Re-Mark Jefferson, Georgia 30549 WKD Project Number 20160013.00.AT

ADDENDUM NUMBER 3 BID DATE: April 22, 2016, 10:00 a.m. April 19, 2016

TO ALL BIDDERS:

Following are the responses to queries made by prospective bidders and received by Engineer.

1. Question:	What should cracks be filled with? Emulsified asphalt & aggregate or coal tar sealant? Can you please clarify?
Response:	The bidder is directed to fill the cracks either with emulsified asphalt & aggregate or with coal tar sealant. Both materials are acceptable.
2. Question: Response:	Do the pavement markings need to have two full applications of the paint? Yes.
3. Question:	Would you kindly assist me in obtaining a plan holder's list of contacts, and let me know whether or not any addenda have been issued.
Response:	Plan holder's list and the addenda is available via the Plan Room tab at <u>www.wkdickson.com</u> .

Receipt of this addendum should be acknowledged under Schedule of Work on Page I-53 of your Single Prime Bid form.

Sincerely,

W.K. Dickson & Co., Inc.

P. G. Parikh

Paresh J. Parikh, PE, LEED AP, PMP Project Manager