

ADDENDUM NUMBER ONE

September 13, 2023 Page 1 of 1

Raton Aquatic Center repairs and maintenance project

The Project Manual and the Floor Plan dated September 1, 2023 are revised as described in this Addendum. When in conflict with other information issued prior to the date of this addendum then this addendum takes precedence. All cost and schedule implications of these revisions are to be incorporated into the Bid.

Project Manual

Access Panels, page 8 of 8

Change "~~Access Panels will be nominal 12" x 12"~~ to
"Access panels will be nominal 12" x 12" and 18" x 18"

Floor Plan

At men's room showers, change the label at the three north showers reading

"~~No new access panels required~~" to

"Install new 12"x12" and new 18"x18" stainless steel access panels at each"

At women's room showers, add to the label at the two east showers

"Install new 12"x12" and new 18"x18" stainless steel access panels at each"

END OF ADDENDUM NO. ONE