



WILLIAMSON COUNTY

Leslie Mitchell, CPPO, CPPB
1320 West Main Street, Suite 130
Franklin, Tennessee 37064
(615) 790-5868
lesliem@williamson-tn.org

November 21, 2017

Addendum #1 for Bid for Fire Alarm at Franklin Rec Center Bid Opening Date November 30, 2017

Following are questions received and Williamson County's responses regarding the above bid:

- Q. What are the part numbers for the equipment specified?
A. *Silent Knight non-proprietary*
- Q. Is there any demo required?
A. *Remove old system and replace with new*
- Q. Is the cable/wire infrastructure to be replaced?
A. *No*
- Q. Is current system design up to code?
A. *As far as we know. It is up to the contractor to make sure it is up to code when finished.*
- Q. What is the work schedule (after hours, weekends...)?
A. *Preferably during open hours, but other arrangements can be made for after hours if needed.*
- Q. Are plans of the existing buildings and/or fire alarm system plans available (hard copy, PDF, AutoCAD)?
A. *We have the original plans for the building but many renovations have been made over the years.*
- Q. Will fire watch be required?
A. *Williamson County will provide Fire Watch if needed.*


In pool and moisture areas devices shall be water and/or moisture resistant.

Building consists of 12+/- manual pull stations, 4 +/- Photo smoke detectors, 7+/- duct detectors, 2 +/- heat detectors, 1 +/- waterflow switches, 1 +/- Supervisory switch, 17 +/- Horn/strobe.

Contractor will provide schematic of devices to correspond with panel legend.

Upgrades of new devices to bring building up to code if needed.

Contractor responsible for permits and drawings.


Leslie Mitchell, CPPO, CPPB, Purchasing Agent

LM/lw

REVISED
Minimum Specifications
Replacement of Fire Alarm System
Williamson County Franklin Recreation Complex, 1120 Hillsboro Road, Franklin, TN 37064

Mandatory pre-bid conference will be held at the site on Tuesday, November 21, 2017 at 9:00 a.m.

Williamson County Property Management is in the process of standardizing all fire alarm panels to the Silent Knight System as current systems expire.

Scope of work:

Removal of current fire alarm system and replacement with an equivalent Silent Knight Non-Proprietary Panel and Equipment. All bids to include Fire Watch if needed. Contractor responsible for all permits.

Items to include for replacement:

- 1 Silent Knight Fire Alarm Control Panel
- 1 Power Supply
- 12 Manual Stations
- 5 Smoke Detectors
- 3 Heat Detectors
- 17 Duct Smoke Detectors
- 19 Relays
- 17 Remote Test Switches
- 4 Monitor Modules
- 20 Horn/Strobes

Total Bid \$ _____

Estimated time to complete work after notice to proceed _____

The bidder has received the following addenda:

Addendum # _____ Dated _____
Addendum # _____ Dated _____
Addendum # _____ Dated _____

Company Name _____

Physical Address _____

Remittance Address _____

Authorized Signature _____

Printed Name _____

Phone _____ Fax _____

Email Address _____

Date _____