

## ADDENDUM NO. 1

<b>DATE OF ISSUANCE:</b>	<b>February 12, 2024</b>
<b>PROJECT:</b>	<b>12<sup>th</sup> Street Elementary School Roof Replacement 6501 South 12<sup>th</sup> Street Portage, Michigan 49024</b>
<b>OWNER:</b>	<b>Portage Public Schools</b>
<b>ARCHITECT'S PROJECT NO.:</b>	<b>023187.00</b>
<b>ORIGINAL BID ISSUE DATE:</b>	<b>February 2, 2024</b>

---

### **SCOPE OF WORK**

This Addendum includes changes to, or clarifications of, the original Bidding Documents and any previously issued addenda, and shall be included in the Bid. All of these Addendum items form a part of the Contract Documents. The Bidder shall acknowledge receipt of this Addendum in the appropriate space provided on the Bid Form. Failure to do so may result in disqualification of the Bid.

### **CHANGES TO PREVIOUSLY ISSUED ADDENDA**

Not applicable.

### **CHANGES TO SPECIFICATIONS**

#### **ADD-1 Item No. S-1 - Asphalt Shingles Basis of Design**

Refer to Specification Section: 07 3313 ASPHALT SHINGLES

Provide:

2.2 GLASS-Fiber Reinforced Asphalt Shingles – Basis of Design

A. Products: Basis of Design – [Dimensional] GAF Timberline UHDZ – 30 year stain guard, Pro Limited Warranty

6. Alternate Manufactures of equal or greater compliance are acceptable.

#### **ADD-1 Item No. S-2 - Existing Sheathing Information**

Refer to Specification Section: 01 2200 UNIT PRICES

The existing Roof Sheathing is 3/4 inch CDX Fire Treated Plywood.

**END OF ADDENDUM.**