

FLINT RIVER PUMP STATION EMERGENCY GENERATOR
BID #16-004
CITY OF GRIFFIN

FROM: PARAGON CONSULTING GROUP, INC.
118 NORTH EXPRESSWAY
GRIFFIN, GA 30223

TO: ALL BIDDERS OF RECORD

RE: Addendum No. 2, dated August 13, 2015

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated July 2015.

This Addendum consists of one (1) page.

CONTRACT DOCUMENTS AND SPECIFICATIONS

- Add. 1.1 **Clarification:** Due to the rules governing the City of Griffin bid process a revised set of specifications cannot be released once the original specifications are published. For this reason the revised specifications were not included with Addendum #1 as originally intended. This Addendum (#2) addresses specific additions to the specifications as originally published.
- Add. 1.2 **Modification:** Item D. in section 2.05 ACCESSORIES of the Emergency Generator specifications shall be changed to read: "Battery rack, batteries and battery cables shall be supplied by the Manufacturer as required."
- Add. 1.3 **Modification:** Item F. shall be added to the end of section 2.05 ACCESSORIES of the Emergency Generator specifications and shall read: "The generator shall be supplied with a 20 Amp, UL Labeled/Listed battery charger that is pre-wired to the accessory 120/208 volt, single phase, 3 wire panel provided by the manufacturer."
- Add. 1.4 **Modification:** Item F. shall be added to the end of section 2.05 ACCESSORIES of the Emergency Generator specifications and shall read: "The manufacturer shall provide in the generator set a 120/208 volt, single phase, 3 wire panel with all required branch breakers for power to all accessories required for a complete installation as per the specifications. All accessories shall be pre-wired to this panel; that require power. All wiring shall be in accordance with NFPA 70, National Electrical Code, 2014 edition."

End of Addendum No. 1