

FLINT RIVER PUMP STATION EMERGENCY GENERATOR
BID #16-004
CITY OF GRIFFIN

FROM: PARAGON CONSULTING GROUP, INC.
118 NORTH EXPRESSWAY
GRIFFIN, GA 30223

TO: ALL BIDDERS OF RECORD

RE: Addendum No. 1, dated August 12, 2015

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated July 2015.

This Addendum consists of two (2) pages and revised Technical Specifications consisting of nine (9) pages.

CONTRACT DOCUMENTS AND SPECIFICATIONS

Add. 1.1 **Question:** The scope on page 4 states this is to supply a generator, however the scope / specs on page 27 states to provide and install. Which is correct?

Answer: The scope of the bid is only to supply the generator. The contractor who is building the new pump station is responsible for installation of the generator. The generator vendor/manufacturer is responsible for testing/start-up as required in the specifications.

Add. 1.2 **Question:** I did not see a request for a battery charger, is this correct?

Answer: A battery charger is required. The technical specifications have been revised to include a battery charger and are attached as part of this agenda.

Add. 1.3 **Question:** I did not see a request for engine starting batteries, is this correct?

Answer: Batteries are to be supplied with the generator. The technical specifications have been revised.

Add. 1.4 **Question:** Enclosure sound requirements; 73db at 23 feet is not a standard rating for standard weather enclosures. Db reductions of this amount will require more complex and substantially more expensive sound reduction enclosures. Is 73db at 23 feet a mandatory requirement?

Answer: The enclosure requirements/sound ratings are as stated in the technical specifications.

- Add. 1.5 **Question:** Delivery to the site does not include unloading correct?
- Answer:** Correct. The contractor building the new pump station will be responsible for unloading the generator when it is delivered to the site.
- Add. 1.6 **Question:** Invoice will be paid in full net 30 once the unit is delivered correct?
- Answer:** Yes. The City of Griffin's payment terms are Net 30.
- Add. 1.7 **Question:** Do any additional plans / drawings exist for this generator project?
- Answer:** The construction plans for the Flint River Pump Station Relocation project may be downloaded from the following web address:
- https://www.dropbox.com/s/fxyeryht1m7seuf/Final%20Plan%20Set%206-18-2015_WM.pdf?dl=0
- Add. 1.8 **Clarification:** Due to the tight timeline of the pump station project the bid date for the emergency generator will not be extended.

End of Addendum No. 1