



PURCHASING
AND MATERIALS
MANAGEMENT

City of Myrtle Beach
SOUTH CAROLINA

(843) 918-2170
FAX: (843) 918-2182
www.cityofmyrtlebeach.com

Addendum #02
January 29, 2024
IFB 24-B0025
Compactor Upfit

The purpose of this Addendum #02 to IFB 24-B0025 for Compactor Upfit dated January 29, 2024 and previously amended on January 11, 2024, is to change the bid opening date and time and to provide answers to the following submitted questions:

1. Do we take the concrete back to a certain point towards the road for the slope or do we take the concrete all the way to the road?

The concrete should be taken all the way to the road.

2. The project on Withers Road is to compactors. Does this mean this will be 30 feet wide which will be the 15 feet times two?

The new concrete pad should be the same size as the one being taken out. From outside edge to outside edge.

3. Is all existing fencing to be removed?

All existing fencing shall be removed.

4. On the stem wall/curbing around the perimeter, I see where this is 6 inches wide, how tall does this need to be?

Curbing adjacent to a non-permeable surface shall be 6" as stated in the detail.

The bid opening date and time is hereby changed. All bids must be received by the Procurement Office at 3231 Mr. Joe White Avenue, Myrtle Beach, SC 29577 prior to 11:00a.m. (local time) on Monday, February 5, 2024.

Thank you,

City of Myrtle Beach
Brandon Hancock
Purchasing Office/Buyer
Email: bhancock@cityofmyrtlebeach.com