

WILLIAMSON COUNTY GOVERNMENT

Addendum #1 Sally Port Doors Bid Date October 22, 2020

Williamson County has received the following question:

- Q: Could you please tell me if the existing power for these doors is single or three phase?
- A: The operators are single phase 115v.

