

**ARLINGTON COUNTY, VIRGINIA
OFFICE OF THE PURCHASING AGENT**

INVITATION TO BID NO. 23-DES-ITBPW-341

ADDENDUM NO. 2

Arlington County Invitation to Bid No. 23-DES-ITBPW-341 for Generator Replacement for Ethan Allen is amended as follows:

1. Bid Due Date is hereby changed to:

ELECTRONIC SEALED BIDS WILL BE RECEIVED BY ARLINGTON COUNTY VIA VENDOR REGISTRY UNTIL **3:00 P.M. EST ON THE 5TH DAY OF JANUARY 2023.**

The County will conduct a virtual bid opening via Microsoft Teams Application (APP). Bidders interested in viewing the public bid opening must download the APP and join the meeting via the Microsoft Teams APP and enable audio, video or both. The link to join the virtual bid opening is provided below:

[Join Microsoft Teams Meeting](#)

+1 347-973-6905 United States, New York City (Toll)

Conference ID: 396 253 195#

2. Clause 4. TIME FOR COMPLETION in Section II. Agreement and Contract Terms and Conditions has been revised as follows:

Work under this Agreement shall achieve Substantial Completion no later than **Four Hundred Thirteen (413)** consecutive calendar days after the commencement date given in a Notice to Proceed provided by the County to the Contractor, subject to any modifications made as provided for in the Contract Documents. This **Four Hundred Thirteen (413)** day period shall be the Period of Performance for Substantial Completion. No Work shall be deemed Substantially Complete until it meets the requirements of Substantial Completion set forth in the General Conditions. Final Completion of the Work shall be completed no later than thirty (30) calendar days after the date of acceptance of Substantial Completion by the County Project Officer. Work will not reach Final Completion until it meets the requirements set forth in the General Conditions.

Unless otherwise provided, no claims for early completion are allowed.

3. Vendor Questions

A list of vendor questions and answers is attached.

The balance of the solicitation remains unchanged.

Arlington County, Virginia

Sy Gezachew

1

ITB No. 23-DES-ITBPW-341

Addendum No. 2

Procurement Officer

RETURN THIS PAGE, FULLY COMPLETED AND SIGNED, WITH YOUR BID:

BIDDER ACKNOWLEDGES RECEIPT OF ADDENDUM NUMBER 2.

FIRM NAME: _____

**AUTHORIZED
SIGNATURE:** _____ **DATE:** _____

Vendor Q&A

1. Will existing generator be turned over to Arlington or do we need to dispose of it? **Dispose**
2. Based on the information provided, it appears that this system is an "Optional Standby System" per the definition found in NEC Article 702.2. Please confirm. **Confirm**
3. Please provide information on the existing insulation installed on the ceilings, columns and walls. **We do not have additional information on the insulation.**
4. Please provide As-Built drawings for the building: Site, Structural, Architectural, Mechanical, Electrical. **We do not have as-builts to provide, and the design documents should be sufficient.**