



ADDENDA #2
ITB NO. 1005-0-2021/LD
ENHANCED SECURITY PROJECT

DATE: 6/24/21

A. The purpose of this addendum is to provide clarification to vendor questions:

1. **Question:** Specification for Aluminum Storefront indicate YKK North America as basis design. What is the acceptable equal manufacturers?

Answer: Acceptable equal manufacturers are listed in specification 08 41 13 section 2.1 B.

2. **Question:** Drawings indicate a 4” speak hole at Storefront Type C. Specification indicate insulated/impact glass. Please provide clarification.

Answer: Contractor to provide impact resistant glazing with 4” speak holes, basis of design Covenant Security Equipment model CSE-HT-SC-100 Amplified Speak-thru, battery operated, non-bullet resistant, 4”-5” opening size with adapter plate (AP 5) as indicated on storefront “C” in the contract documents.

All other terms and conditions of this ITB remain unchanged.

This Addendum shall be considered an integral part of the ITB and Contract Documents and this Addendum must be signed and returned with your submittal **by 2:00 p.m. on June 30, 2021**, and acceptance on the Bid Form designated in Section 7.2. Failure to comply may result in disqualification of your bid submittal.

Lenora S. Darden

Lenora Darden, MCPP, CPPB, CPSM
Purchasing Supervisor

Acknowledgement is hereby made of Addenda #2 to ITB# 1005-0-2021/LD: Enhanced Security Project.

Authorized Signature

Firm

Printed, Title

Date

Email Address