



**IFB #365-20 CULVERT RENOVATIONS PROJECT FOR DAWSON COUNTY
ADDENDUM #1**

Bid Closing Date: April 28, 2020, at 10:30AM, EST
Bid Issue Date: April 3, 2020
Addendum Issue Date: April 21, 2020
By: Melissa Hawk, Purchasing Manager

The following are amendments to the IFB #365-20 Culvert Renovations Project for Dawson County:

1. After further consideration for Structure #317, at Baily Waters Road, the county will allow this road to be temporarily closed during replacement, as per the General Terms and Conditions of the IFB. Please add a note to the Price Proposal Form for Structure #317 with your company's measured footage for this structure. Please list the cost for this task in the total cost for task block on the Price Proposal Form. Please be aware that this structure replacement will be for the total replacement to match existing hydraulics.
2. The county received a request for a materials substitution. After review by the Public Works department, GeoCast Geopolymer Mortar for concrete pipes and culverts rehabilitation has been approved as long as the hydraulics are not compromised nor the structural integrity.
3. All dates, other specifications, terms and conditions remain the same as posted in the RFP document.

The following are questions and answers to the IFB #365-20 Culvert Renovations Project for Dawson County:

QUESTION: When is the due date of the bid responses.

ANSWER: April 28, 2020, to be received no later than 10:30 a.m., by the Purchasing Manager.

QUESTION: How much right of way does the county have?

ANSWER: 60 Feet

QUESTION: What length of Bailey Waters Road is needed for the 26' wide road bed?

ANSWER: The length needs to be 26' minimum over the pipe.

QUESTION: How much of the shoulder if required?

ANSWER: 2', anything less shall be approved by the Public Works Director.

QUESTION: How much clearing is required?

ANSWER: To be determined by the Contractor and approved by the Public Works Director prior to completion.

QUESTION: Will lining contractor need to be pre-qualified with county?

ANSWER: No, Dawson County does not have a pre-qualification program.

QUESTION: Can Sweetwater Juno be closed during this project and if so, when and for how long?

ANSWER: Dawson County prefers only one lane closure at a time and no overnight closures. All traffic control, including road closures, road signage is the responsibility of the Contractor as per the IFB General Terms and Conditions.

QUESTION: Structure #317 Is larger than 96”, how would you like to proceed with the bid?

ANSWER: Please add a note to the Price Proposal Form for Structure #317 with your company’s measured footage for this structure. Please list the cost for this task in the total cost for task block on the Price Proposal Form. Please be aware that this structure replacement will be for the total replacement to match existing hydraulics.

Company Name

Signature of Authorized Representative

Title

Date

THIS DOCUMENT MUST BE COMPLETED AND SUBMITTED AS PART OF YOUR PROPOSAL

IFB #364-20 Dawson County Paving Project for Two Collector Locations