

CLAYTON COUNTY WATER AUTHORITY

Request for Bid

VETERANS PARKWAY STORM SEWER REPLACEMENT

Bid Opening: Thursday, January 5, 2017 at 10:00 a.m. (local time)

A D D E N D U M # 2

Dated: December 20, 2016

*Acknowledgment of receipt of this addendum **MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.***

QUESTIONS:

1. Can a GDOT approved Recycled Concrete Aggregate (RCA) graded aggregate Base (GAB) material be used as an alternate to crushed stone graded aggregate base (GAB)? The GDOT is now using RCA on major projects, and have developed a calculation for payment due to the difference in yield and weight from crushed stone GAB.

Answer: Yes.

2. In addition, the same question, but using GDOT approved #57 RCA (Recycled Concrete Aggregate) as an alternate to crushed stone for backfill proposes? One further note, ADS has approved use of RCA #57 in the installation of their Storm water Flexible pipe.

Answer: Yes.

3. Can we please have a pre bid sign in sheet copy emailed to us?

Answer: See pages 2 - 4 of this Addendum.

SIGNATURE

COMPANY NAME

DATE

CLAYTON COUNTY WATER AUTHORITY

Request for Bid

VETERANS PARKWAY STORM SEWER REPLACEMENT

Bid Opening: Thursday, January 5, 2017 at 10:00 a.m. (local time)

ADDENDUM # 2

Clayton County Water Authority

Non-Mandatory Pre-Bid Meeting

Wednesday, December 14, 2016 at 10:00 a.m. (local time)

1600 Battle Creek Road, Morrow, GA 30260

Department: Stormwater

Bid Title: Veterans Parkway Stormwater Improvements Phase #2

Bid Date and Time: Thursday, January 5, 2017 at 10:00 a.m. local time

Page 1 of 3

COMPANY NAME	REPRESENTATIVE	PHONE NUMBER	EMAIL ADDRESS
Crawford Grading & Pipeline	Stuart Lee	770-927-0413	SLee@crawfordgrading.com
DAF Concrete Inc.	Audrey Clyde	404 433 8824	daf_concrete_inc@yahoo.com
Brtu construction inc.	Joshua Kennedy Sintayehu Areda	Cell- 770-545-0927 office - 404-228-9074	JKennedy.DDnus@gmail.com Sint@brtuconstruction.com
Brtu construction inc	Denver Davidson	770-629-8570	dend122@yahoo.com
Stephens Industries	Alexsa Rowe	cell: 404 683 8424 office: 770 986 000	arowe@stephensmids.com
Kemi Const. Co., Inc	Verna Akinpelu	404 349-8228	VAkinpelu@kemi.construction.com
LARRY DOBBS CONSTRUCTION	Rick TAYLOR	770-714-9646	rtaylor@maxairinc.com
Chris Clark ↔	Stephens Industries	770 545-1214	cclark@stephensmids.com

CLAYTON COUNTY WATER AUTHORITY

Request for Bid

VETERANS PARKWAY STORM SEWER REPLACEMENT

Bid Opening: Thursday, January 5, 2017 at 10:00 a.m. (local time)

ADDENDUM #2

Clayton County Water Authority

Non-Mandatory Pre-Bid Meeting

Wednesday, December 14, 2016 at 10:00 a.m. (local time)

1600 Battle Creek Road, Morrow, GA 30260

Department: Stormwater

Bid Title: Veterans Parkway Stormwater Improvements Phase #2

Bid Date and Time: Thursday, January 5, 2017 at 10:00 a.m. local time

Page 2 of 3

COMPANY NAME	REPRESENTATIVE	PHONE NUMBER	EMAIL ADDRESS
LAYNE HEAVY CIVIL	FRANK MAINES	770 969 4040	FRANK.MAINES@LAYNE.COM TIM.DUNN@LAYNE.COM
Miche Roy, Inc. Matt Andrews	Matt Andrews	770 567-3030	mattd@mcleroyinc.com
J.G. Leone Enterprises, Inc.	John Leone	770-213-3399	John@jbleone.com

CLAYTON COUNTY WATER AUTHORITY

Request for Bid

VETERANS PARKWAY STORM SEWER REPLACEMENT

Bid Opening: Thursday, January 5, 2017 at 10:00 a.m. (local time)

ADDENDUM #2

Clayton County Water Authority

Non-Mandatory Pre-Bid Meeting

Wednesday, December 14, 2016 at 10:00 a.m. (local time)

1600 Battle Creek Road, Morrow, GA 30260

Department: Stormwater

Bid Title: Veterans Parkway Stormwater Improvements Phase #2

Bid Date and Time: Thursday, January 5, 2017 at 10:00 a.m. local time

Page 3 of 3

COMPANY NAME	REPRESENTATIVE	PHONE NUMBER	EMAIL ADDRESS
Site Engineering Inc.	Carter Hewitt	770-876-9125	Carter@siteengineering.com