

## **Addendum #2**

Project Identification: *Nash St. Streetscape #2023-61-RA  
Wilson, North Carolina*

Issue Date: *March 18, 2024*

Answers to Contractor Questions:

1 – In regard to the light pole footings, will a line item be added for those, or will that be paid as a change order?

*A Line Item will be added for Miscellaneous Concrete. This line item will cover for the light pole footings, trash can pads, and bench pads.*

2 - Regarding the trash can pads, bike rack pads, and bench pads, how are these items to be paid? There are no line items for this.

*They will be paid into the new line item Miscellaneous Concrete. Bike Rack Pads will be paid as incidental to Bike Rack Installation.*

3 – For the 6” PVC Underdrain, how will this line item be paid? There is no line item for this.

*6” PVC Underdrain will be paid as incidental to Irrigation Lump Sum.*

4 – It says in the plans that the additional parking is to be full depth per city standards. Can you elaborate on what detail you would like us to follow?

*The additional parking is to match what is existing on Nash St.*

5 – Will Nash St. be able to stay closed throughout the duration of the project, or will the street have to be opened at the end of each working day?

*Nash St. will be closed for the duration of the project.*

6 – Will the pedestrian cross walk being installed, or should we plan for this work not to take place?

*Pedestrian crosswalk will not be installed. The wheelchair ramps will not be installed, instead match curb and gutter and grass verge. Within the roadway will just be asphalt, no pavers will be installed as shown for the crosswalk.*

7 – What kind of patching detail would you like us to follow for the storm drain/utility installation?

Screenings up to subgrade?

*Patching detail will also be to match existing pavement. If soil removed is suitable then it can be reused, if not then screenings will need to be used up to subgrade.*

Attachments:

Updated Bid Form