




Engineering  
Landscape Architecture  
Surveying

## ADDENDUM NO. 2

**TO:** Prospective Bidders

**FROM:** Bill Lester, P.E.   
LKC Engineering, PLLC

**PROJECT:** Randolph County, NC  
Uwharrie Pump Station & Force Main Improvements  
Project Number: SRP-W-ARP-0205

**DATE:** October 31, 2023



Contractors' attention is brought to the following instructions and/or changes to the Bid Documents:

**This addendum shall clarify a few additional items regarding the project. The revisions and clarifications herein shall be incorporated into the contract documents and shall be considered to take precedence where noted.**

**1. Electrical Improvements**

Please note that the electrical drawings depict upgrades to the proposed service, wiring and panel related improvements for this project. A new 200 amp service is required, as well as a new automatic transfer switch for the generator related to the service upsizing. The Contractor must also note that the proposed pumps shall meet the minimum horsepower requirement or concerns may exist related to generator and electrical sizing for the work. The cost for the electrical upgrades and all associated work for a complete project shall be included in the cost for the work as presented in the Bid Form.

**2. Pumps**

Homa pumps were inadvertently removed from the prequalified, or equal, listing and is considered acceptable for models that meet the conditions of the project.

**3. Pre-Bid Meeting Attendee List**

A copy of the Pre-Bid Meeting Attendee List is attached for your reference.

**The bid opening remains scheduled for Thursday, November 2, 2023, at 2:00 pm.**

**PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID FORM AND BY CONTACTING: Tanya Medlin at [tanya@lkcengineering.com](mailto:tanya@lkcengineering.com).**