



Alex W. Alkire, AIA, CSI, CCS, LEED AP
Edward M. Brummel, Jr., AIA, CSI, CCS
Anne J. Nieman, RID, ASID

PWBA Architects, Inc.

529 South Perry Street | Suite 15
Montgomery, AL 36104-4636
334.244.4990

10/9/2023 10:09 a.m.

PREMISE HEALTH CARE

(At former Whitney Hancock Building)
124 West Main Street
Prattville, Alabama 36067
PWBA 2023-0702

ADDENDUM NO. 2

October 09, 2023

BIDS DUE: 2:00 PM CT, Tuesday, October 10, 2023.

DIRECTED TO: All Bidders of Record and all others to whom Bid Documents have been issued.

GENERAL:

1. This **ADDENDUM** is hereby made part of the Bid/Contract Documents and, as such, must be acknowledged on the Bidder's Proposal Form. Failure to do so may subject the Bidder to disqualification. The following conditions take precedence over conflicting conditions in the Specifications, on the Drawings and in other Contract Documents. The Bid/Contract Documents are hereby amended as follows:

DRAWINGS:

2. Refer to **Sheet E001:**
 - A. Add note as follows:

Emergency lighting is provided throughout the new site in accordance with the applicable codes. Specified fixtures where noted by "NL shall be unswitched and shall be provided with emergency battery packs. Replace existing lighting in canopy / exterior soffit with new fixtures with battery packs. See also revised lighting fixture schedule".
 - B. Add note as follows:

"Fire alarm alterations shall be provided to meet the requirements of applicable codes and standards the fire alarm contractor shall submit shop drawings for review and approval by the Fire Marshall"
3. Refer to **Sheet E200:**
 - A. Add note as follows:

"See revised new -floor plan- lighting and new work- floor plan power and auxiliary and notes"

4. Refer to **Sheet A105**:

- A. General Contractor may work overtime to complete project on schedule except for Sundays, when no work on site is to be scheduled.

END OF ADDENDUM NO. 1

Prepared by:

PWBA Architects, Inc.

Jay Ruffer