

Propane Questions 17-19

1. Since we own existing equipment-Pumps that already in place-2 ea.
2. Can we run line to 18,000 gallon transport tank in order for buses to refuel as they are now? And use our existing pumps? [Yes](#).
3. Is Bibb co BOE going to be responsible for having power lines moved if necessary for 18,000 tank to be installed? This came up when we met with Fire marshall. [Yes](#).
4. What size tank would be installed at second location? [18,000](#)
5. How many dispenser and pumps does the Bibb Co. Boe require per location? [2 of each](#)
6. What fuel management system in the district currently using ? [Phoenix](#)
7. When does the install take place after July 2017 or after July 2018 ? [July 2017](#)