



St. Johns River

Water Management District

Ann B. Shortelle, Ph.D., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940
On the internet at www.sjrwmd.com.

DATE: October 12, 2020
TO: Prospective Respondents
FROM: Amy Lucey, Contracts Administrator
SUBJECT: Addendum #2 to Quote Request # 36199, Fabricate Steel Access Walkways

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your quote documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

Q1: On Drawing S-4, 1 ½ Schedule 40 Aluminum Hand Railing will have an outside diameter of 1.9” (is this measurement correct?) or do you need the outside diameter of railing pipe to equal 1.5 inches outside diameter?

A1: 1-1/2” is the nominal diameter. The actual diameter is 1.9”.

Q2: Quote Request 36199 Quantity Request (6) 15’-0” long walkway structure and drawing C-1 specifies (2) 15’-0” long walkway structures. Please advise on the exact quantity.

A2: The District is requesting 6 separate 15-foot platforms. This will allow us to install 3 – 30-foot platforms at various locations.

Q3: As per Note IV item 3 task identification, can the steel, which consist of all the H Piles be hot dip galvanized?

A3: As an alternative to painting, the HP8x36 piles and beams may be hot-dip galvanized in accordance with ASTM A123 Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products. The required minimum zinc coating thickness shall be 3.9 mils.

NOTE: The Quote Request Due Date **remains** 3:00 p.m., **Thursday, October 29, 2020**

Please acknowledge receipt of this Addendum on the **Quote Cost Schedule** FORM provided in the quote package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.