

**ADDENDUM NUMBER: 2**  
**DATE: February 9, 2018**

**PROJECT: Belle Meade 2018 Stormwater Infrastructure Improvements – Belle Meade Blvd. and Iroquois Avenue  
City of Belle Meade, TN  
Bid Documents Dated January, 2018**

---

The following item(s) are amended or **clarified** by this addendum:

**PLEASE NOTE THE FOLLOWING QUESTIONS. ANSWERS (IN RED) ARE PROVIDED BY THE CONSULTING ENGINEER ON THIS PROJECT:**

1. Lane Closure of Belle Meade Blvd.: If this lane is to remain closed throughout the duration of the project due to open excavations and equipment, will lighted delineation markers be required for night time lane delineation? If the lane is to be reopened each night, please specify. **The lane must be reopened each night.**
2. Erosion control measures: Will other erosion control measure be required besides the inlet protection. It appears that some may be required along the lot frontage and also along the closed lane of traffic. Is it at our discretion to install as needed? **The site generally lies in a “bowl” and is why more sediment control measures were not specified. However, the contractor must comply with the EPSC notes on Sheet C001.**
3. Gas Main: Is approximate location of gas main known? **None was marked after the One-Call. Please refer to the Utility General Notes on Sheet C001.**
4. Street Signs: Can these be reused? **Yes provided the condition after the contractor removes them and reinstalls them is acceptable to the City.**

If there are any questions, please contact Beth Reardon, City Manager or Larry Smith, Public Works Director, at 615-297-6041 or by email at:

[breardon@citybellemeade.org](mailto:breardon@citybellemeade.org)  
[lsmith@citybellemeade.org](mailto:lsmith@citybellemeade.org)