



OFFICE OF PROCUREMENT SERVICES
335 FOUR MILE ROAD
CONWAY, SC 29526-6005

AMENDMENT/ADDENDUM No. #3

Posting Date: Friday, March 20, 2020

Solicitation Number: 1920-52MJ

Description: Track and Field Improvement Program Phase 1

AMENDMENTS/ADDENDUM TO SOLICITATION: (a) The Solicitation may be amended at any time prior to opening. All actual and prospective Offerors should monitor the following web site for the issuance of Amendments: <https://vrapp.vendorregistry.com/Bids/View/BidsList?BuyerId=2f302e8a-69b0-407b-a21a-3368d004365e>. (b) Offerors shall acknowledge receipt of any amendment/addendum to this by identifying the addendum number and the date of issuance with the Bidder's initials in the spaces provided on the *Official Bid Form* (c) If this solicitation is amended, then all terms and conditions which are not modified remain unchanged. [02-2A005-1]

QUESTIONS FROM OFFERORS – AMENDMENT/ADDENDUM (JUN 2017): The solicitation is amended as provided herein. Information or changes resulting from questions will be shown in a question-and-answer format. All questions received have been reprinted below. The "District's Response" should be read without reference to the questions. The questions are included solely to provide a cross-reference to the potential offeror that submitted the question. Questions do not form a part of the contract. The "District's Response" does. Any restatement of part or all of an existing provision of the solicitation in an answer does not modify the original provision except as follows: underline text is added to the original provision. Stricken text is deleted. [02-2A097-1]

Substitution Request/Approved Equals:

1. Specification Section 321823.39 Synthetic Running Track Surfacing, Part 2.1C Basemat Structural Spray Track Surfacing. The following additional products are approved for bidding:
 4. Hellas Construction, Inc.
 - a. Contact: Patricia Rodriguez @ (512) 250-2910
 - b. Product: epiQ TRACKS V300 System (note: the product submitted in the substitution request is for a non-porous basemat structural spray system. The actual equivalent product to the project specification would be epiQ TRACKS S200)
 5. CONICA AG
 - a. Contact: Luke Brown @ (615) 499-3624
 - b. Product: Basemat Structural Spray (Porous): CONIPUR SP
2. Specification Section 321823.39 Synthetic Running Track Surfacing, Part 2.1C Basemat Structural Spray Track Surfacing. The following products are not approved for bidding: California Sports Surfaces Plexitrac Accelerator Polyresin Track System

Offerors Questions:

1. **Question:** In the Special Bidder Qualifications section of the Summary of Services Required (page 3 of the Invitation to Bid) has item C which states: "The On-site Project Manager/Superintendent shall provide a list of completed facilities within the past 5 years. This list shall include a minimum of 5 running tracks which are certified to meet NFSHSA rules and regulations in the past 5 years utilizing the products specified in the attached specifications." Please confirm this requirement is meant only for the Track & Field Vendors, not General Contractors.

Answer: This reference in the Special Bidder Qualifications is from Specification Section 321823.39 Synthetic Running Track Surfacing Part 1.3.A.2.b and refers to the Track & Field Synthetic Surfacing Contractor On-Site Project Manager/Superintendent. There are similar requirements for Track & Field Paving Contractor On-Site Project Manager/Superintendent listed in Section 321216.36 Athletic Track Asphalt Paving Part 1.3.C.

Specifications have been revised, changes to Contract Documents:

- Specification Section 116833 – Outdoor Sports Equipment

- Part 1.1 Work Included, Subpart A.1 Football Equipment:

Add the following language:

"b. Play clock support post padding"

- Part 1.2 Submittals, Subpart B.2 Product Data:

Add the following language:

"2. Play clock support post padding"

- Part 2.1 FOOTBALL EQUIPMENT:

Add the following language:

"B. Play Clock Support Post Padding

- 1. I-Beam Post Padding:

- a. Square design x 4-ft height (verify in field)

- b. Premium fully encased construction

- c. 2" high density foam and outdoor vinyl

- d. Standard vinyl colors

- 2. Products and Suppliers:

- a. Sportsfield Specialties, Inc. (www.sportsfieldspecialties.com)

- i. Model #SBP6 (6" max. inside dimension – verify in field)

- b. Or approved equal."

Refer to attached revised plan sheets for Loris High school, sheets C-002 and C-100 to show the removal of the field fencing, changes to the filed gates, and play clock post padding.

HORRY COUNTY SCHOOLS

By: _____

Robin B. Strickland, CPPB
Procurement Officer