

# ADDEMDUM NO. 1

City of Springfield, TN

## **Travis Price Parking Lot Expansion**

Contract #PW2210

November 23, 2022

This addendum forms as part of and modifies the Contract Documents to be opened on date November 29,2022. Acknowledge the receipt of this Addendum by attaching to the bid documents and initialing the bid form in the space provided below. Failure to do so may subject the Bidder to disqualification.

### **REFER TO PROJECT MANUAL:**

#### **BID FORM:**

Bid form has not been modified.

#### **CLARIFICATION:**

Riprap #200 in the bid form is a the same as TDOT A-1 Riprap

#### **QUESTIONS AND ANSWERS:**

Do you know approx when this project will be scheduled to begin?

#### **It will be spring after most asphalt plants open up**

Is there any clearing associated with this work that will be the responsibility of the contractor?

**This is in a field, no bushes or trees, the excavated material item is only "clearing" item and this is cutting to depth for base material and asphalt to maintain current grades.**

Special Provision 108 says we have 15 days to commence work from the Notice of Call-Out and "fully complete the **portion** stipulated in the Call-Out within 25 Calendar Days". It also says the project is to be fully completed within 100 Calendar Days. Can you elaborate as to what is to be completed within 25 days? This is a note used by the city for projects that have not had sufficient progress to meet the deadlines, to calculate liquidated damages. 100 days

**This was a note for contracts that have staged deadlines, this is not relevant for this project as it is not staged and is simply a calendar day project**

1. Can we substitute a clean washed rock in lieu of River Rock as per item #107. River Rock is considerably more expensive.

**Can not use limestone rock, as this will cause clogging at a later date. Rocks must be 1.25" in diameter in the French drain backfilling.**

What is the purpose of item #111 - 6" Plastic Piping for Drainage and is there any specific bedding or cover associated with this pipe?

**This is piping extending the French drain under the sidewalk to the ditch**

Does the City have a nearby area to waste the approx 1,450 CY of excavated material?

**Yes, the city will provide haul off with trucks but contractor must load. May stockpile on site and load trucks on an agreed-on schedule.**

Received Addendum 1 Initials: \_\_\_\_\_