

**ADDENDUM NO. 1**

DATE: August 23, 2017  
TO: All Proposers   
FROM: Julie Smith Maxwell, Procurement Specialist  
SUBJECT: Addendum No. 1 – Onsite Inspection, Testing, and Documentation of Fire Hoses and Ladders  
BIDS TO BE OPENED: August 30, 2017, at 11:00:00 a.m. Eastern Time

This addendum is being published to respond to a question asked by a potential proposer regarding the above-referenced Request for Proposals. This addendum becomes a part of the Contract Document and modifies the original specifications as noted.

**Question 1:** Page 5-6, V. Scope of service bullet point 3 states “Nozzles and appliances of various sizes and types.” Are nozzle and appliance testing part of this RFP? If so, can you provide a count for the total nozzles and appliances you would like tested? Can you break the appliances down letting us know how many appliances have pressure relief valves?

Response: Yes, nozzle and appliance testing is included in the scope of service as noted in the RFP. The City provides the following estimates (exact count is not available):

Nozzles:	Appliances:
1” – 75	Piston Intake Valves – 40 – Has pressure relief
1 ¼” – 200	Manifolds Large Diameter – 20 – Has pressure relief
2 ½” – 100	Siamese/Gated Wye/ Wye - 50
	Humat Valve - 30

**END OF ADDENDUM NO. 1**