

March 22, 2019

ADDENDUM TO ADVERTISED CONTRACT

PROJECT NAME: CITY OF HOLLY SPRINGS HICKORY RD @
PALM STREET INTERSECTION
IMPROVEMENT PROJECT

PROJECT NUMBER: RFB #2019-01

CITY: CITY OF HOLLY SPRINGS

AMENDMENT NUMBER: 2

LETTING DATE: MARCH 29, 2019

THE FOLLOWING CHANGES ARE HEREBY MADE TO THIS CONTRACT. THE BIDDER IS RESPONSIBLE FOR MAKING ANY NECESSARY CHANGES IN INK IN THE PROPOSAL. BIDDER SHALL ACKNOWLEDGE THIS AMENDMENT BY CHECKING THE APPROPRIATE SPACE ON THE AMENDMENT CERTIFICATION PAGE.

.....

QUESTIONS/CLARIFICATIONS

1. Is the colored concrete to be integral color or top cast? **Top cast**
2. Is the contractor to grade to the temp slope shown on the cross sections or beyond that is another proposed contour line. **Grade to temp slope shown in revised plans.**
3. Some of the cross sections you are showing a 2:1 slope at the top of the slope. Please clarify. **Grade to temp slope shown in revised plans.**
4. Some of the cross sections are showing Curb and Gutter sitting on top of the slope which this is not reflected within the plans. Why is this? Currently top of slope is raw land. **Anything shown outside of the temp slope line are for info only and will be constructed by the site developer.**
5. Is there a utility adjustment schedule for this project? **See addendum #1 item #16**
6. **Part of this addendum includes the revised Cover Sheet and Revision Sheet for addendum #1.**