

March 28, 2019

ADDENDUM TO ADVERTISED CONTRACT

PROJECT NAME: CITY OF HOLLY SPRINGS HICKORY RD @
PALM STREET INTERSECTION
IMPROVEMENT PROJECT

PROJECT NUMBER: RFB #2019-01

CITY: CITY OF HOLLY SPRINGS

AMENDMENT NUMBER: 4

LETTING DATE: APRIL 12, 2019*

THE FOLLOWING CHANGES ARE HEREBY MADE TO THIS CONTRACT. THE BIDDER IS RESPONSIBLE FOR MAKING ANY NECESSARY CHANGES IN INK IN THE PROPOSAL. BIDDER SHALL ACKNOWLEDGE THIS AMENDMENT BY CHECKING THE APPROPRIATE SPACE ON THE AMENDMENT CERTIFICATION PAGE.

.....

QUESTIONS/CLARIFICATIONS

1. *Change bid date to April 12th, 2019 at 10AM. Same location.
2. Water meters will not be a part of this project. They will be part of the site work project. Delete 2" water meters from the bid schedule. New bid schedule attached.
3. Will the city handle testing? Compaction, concrete, asphalt, etc.? The City of Holly Springs will be responsible for all material testing.
4. Will we be required to place topsoil in landscaped areas, or will that be with a landscape package? The placement of topsoil will be part of the landscape package as a requirement. However, the contractor will need to ensure the beauty strip can sustain sod.
5. On the bid schedule the Junction Boxes were left off. The plans call for a junction box to be placed at the end of the "C" line of storm drain pipe to tie the proposed storm line into the existing line at an existing catch basin. A "JUNCTION BOX" item has been added to the bid schedule.
6. I would like to confirm that there will be only the three (3) addendums for the above referenced project that bids tomorrow (03/29/19) morning. This addendum is the 4th and see No. 1 above for new bid date.