

## ADDENDUM NO. I

**DATE:** 12/23/2021  
**TO:** All Potential Proposers  
**FROM:** Taylor Childress, Procurement Specialist, City of Knoxville  
**SUBJECT:** Addendum No. I to Request for Quotes - Underground Storage Tank Sensor Repair

**PROPOSALS TO BE OPENED:** December 29, 2021 2:30 PM (Eastern Time)

This addendum is being published to provide clarification regarding the above referenced request for quotes. This addendum becomes a part of the contract documents and modifies the original specifications as follows:

### Items for Clarification:

**Question:** I have been successful in the past when the pull string breaks that wraps around the tank to pull the sensor of getting a fish tape around the tank and pulling a new one in.

**Response:** Due to the uncertainty of the method of the method of repair required, the City's intent is to award this quote based on pricing for both the fish tape technique and the specified method of cutting through the concrete. The winning contractor should first attempt to repair it using fish tape. If successful, the City will pay the "fish tape" price. If this is not possible, the winning vendor must break concrete and repair it per the original specifications. Award will be based on the quoted price for the original specification for the concrete cutting method. The revised quote sheet is attached to request both prices.

**End Of Addendum NO. I**

**QUOTE SECTION**

Having carefully examined the specifications detailed above, we hereby propose to furnish the supervision, labor, materials, equipment, delivery, and services as stated for the following sum:

Fish Tape Quote \$ \_\_\_\_\_

Original Specification Cutting Concrete Quote \$ \_\_\_\_\_

GUARANTEE of work completion no later than one month from receipt of City Purchase Order.

Firm Name:

Signature of Quoting Official: \_\_\_\_\_

Telephone: \_\_\_\_\_

Email: \_\_\_\_\_

DUNS #: \_\_\_\_\_