

ADDENDUM NO: 1

REQ NO: 167949

FINAL SUBMITTAL: April 18, 2018 2:00 PM EST

FINAL QUESTIONS: N/A

Department: Waste Resource Division, Public Works

Changes to Bid No. 305065:

Question: The valves that are there now are Henry Pratt butterfly valves. Are you wanting to replace tem with Henry Pratt since that is what is already there? Or are you open to another brand of valve? That may require some calibration for the actuator or possibly even having to get new actuators.

Answer: Waste Resource Division would be open ti other brand valves depending on manufacturer. We would not accept every brand but would evaluate all. I can tell you that we would be okay with a Dezurik brand valve. The most critical aspect is that the lay length of the valve has to be the exact same as the Tratt valve or it will not fit.

Req No: 167949 Pratt Butterfly Valves

PLEASE SIGN ONE (1) COPY OF ADDENDUM AND RETURN TO THE PURCHASING DEPARTMENT. RETAIN THE OTHER COPY FOR YOUR FILES.

Name: _____

Company: _____

**CITY OF CHATTANOOGA
PURCHASING DEPARTMENT
Mark McKeel
City Hall Suite G13
CHATTANOOGA, TN 37402
TELE: (423) 643-7236
FAX: (423) 643-7244**