



Terry McKee, IT & Procurement Director

901 N. Broadway • Knoxville, TN 37917-6699
 865.403.1133 • Fax 865.594.8858
 purchasinginfo@kcdc.org
 www.kcdc.org

Addendum

Solicitation Name	Sewer Line Services at Montgomery Village Q2005	Addendum Number	2	Date	01/29/2020
--------------------------	---	------------------------	---	-------------	------------

This addendum answers questions raised about this solicitation. To aid in readability, the questions are in black, the answers are in **bolded blue**, and the answers follow immediately below.

Q1	When does the 30 completion timeline start?
	Once your engineer's plans have been approved by KCDC.
Q2	What type of pipe is it?
	Cast iron.
Q3	Is pipe bursting an option?
	If approved by your engineer.
Q4	Must we set a new manhole?
	This depends upon what your engineer and the City of Knoxville approve.
Q5	How many laterals come into it?
	At least three.
Q6	Will we tie back in?
	This depends on what you engineer designs.
Q7	Must we notify KAT?
	Yes if your work impedes traffic flow.
Q8	Are there liquidated damages?
	Yes \$100 per day after 30 days but see question 1 for the start of the 30 days.
Q9	How deep is it?
	At one end 18 feet and at the other 8 feet.
Q10	Are there abandoned lines there?
	Yes there are condemned/abandoned water main and fire mains. However Tn. One Call will need to be notified

