

Roane County Purchasing Department
200 East Race Street, Suite #3
Kingston, Tennessee 37763
Phone 865-376-4317 • Fax 865-376-4318

**ADDENDUM #3
BID #2016-21-171
ROOF REPLACEMENT – CENTRAL SERVICE BUILDING**

TO: All Potential Bidders

This addendum forms part of the Bid Documents. It supplements and modifies them as follows:

ITEM #1 – ADDITIONAL INFORMATION

1. The deadline for questions was June 3, 2016.
2. Remove one ply of the existing metal roof.
3. If a pull test is required to maintain manufacturer's warranty, it is the contractor's responsibility and expense.
4. The bid is for approximately 6000 sq ft of reroofing and includes all heated areas of the building. Comments from any individual other than Roane County Purchasing are not binding.

Please return this addendum to the Purchasing Department in the bid envelope. If your bid has already been sent and this addendum does not pertain to bid pricing, you may return it via facsimile.

ACKNOWLEDGMENT OF ADDENDUM

The undersigned acknowledges receipt of Addendum #3 – Bid #2016-21-171.

Name

Title