

ADDENDUM NO. 1 TO CONTRACT DOCUMENTS

Project: Havelock WWTP Influent Pump Station No. 1 Modifications H&S Project No. 30906-301
Owner: City of Havelock Date: June 8, 2022

To All Bidders:

Contractors submitting proposals for the above named project shall take note of the following changes, additions, deletions, clarifications, etc., in the Contract Documents, which shall become a part of and have precedence over anything contrarily shown or described in the Contract Documents, and all such shall be taken into consideration and be included in the Contractor's Bid Proposal.

Refer to attached sheet(s)

The return receipt requested with the communication will be deemed evidence the bidder has received this Addendum and has followed the instructions outlined herein. Please sign, date, clearly print company name, and email this sheet back to Hazen and Sawyer, havelockipsbid@hazenandsawyer.com.


Company Name

Acknowledgement of Receipt

Date

Digitally signed by FARIS E. MATAR

Date: 2022.06.08 14:42:24 -04'00'



Faris E. Matar, P.E.
HAZEN AND SAWYER

CITY OF HAVELOCK
HAVELOCK, NORTH CAROLINA
WWTP INFLUENT PUMP STATION NO. 1 MODIFICATIONS

Addendum No. 1

General:

- Minutes from the pre-bid meeting are provided in **Attachment 1**.

Contract Documents:

SECTION 01 14 00 – COORDINATION WITH OWNER'S OPERATIONS

- Page 01 14 00-6, add the following line items to Section 1.06B:
 - “6. Contractor is responsible for removing existing bypass system in place at the pump station prior to commencing work.”
 - “7. All valves for lines coming into IPS no. 1 shall be closed and plugs shall be provided to ensure wet well isolation during construction.”

SECTION 01 57 40 – TEMPORARY PUMPING SYSTEMS

- Page 01 57 40-4, replace Section 1.04E with the following:
“The temporary pumping system must be monitored and checked daily (minimum of once per 24 hours) during operation by a representative of the Contractor trained and certified by the pump supplier.”
- Page 01 57 40-4, replace the first sentence of Section 1.04G with the following:
“Temporary pumping systems shall be equipped with noise reduction features that limit the noise output to 69 db[A] within 30 feet of the equipment or to 60 db[A] at the nearest property line, whichever is less.”
- Page 01 57 40-8, remove Section 2.01H in its entirety.
- Page 01 57 40-14, replace the last sentence of Section 3.05F with the following:
“The temporary pumping system must be monitored and checked daily (minimum of once per 24 hours) during operation by a representative of the Contractor trained and certified by the pump supplier”

SECTION 43 25 13 – SUBMERSIBLE SOLIDS-HANDLING PUMPS

- Page 43 25 13-12, in Section 2.10C, change the “Insulation” line item from “Class H” to “Class F”.

Addendum No. 1, Attachment 1



HAVELOCK
NORTH CAROLINA

**CITY OF HAVELOCK WWTP INFLUENT PUMP STATION 1
MODIFICATIONS
PRE-BID MEETING
MARCH 31, 2022 @ 1:30 PM**

1. Introductions

- City of Havelock – Owner
- Hazen and Sawyer – Design Engineer

2. Project Description (Not all inclusive)

- Influent Pump Station No. 1 Modifications
- Approximately 200' of force main

3. Bid Opening

- Tuesday, June 14th, 2022 at 2:00 p.m. EST
Havelock City Hall
1 Governmental Ave., Room 134
Havelock, NC 28532
- No bids accepted by City of Havelock in any other location.

4. Interpretation of Contract Documents

- All questions to Hazen and Sawyer attention, havelockipsbid@hazenandsawyer.com. All questions must be emailed.
- Questions should reference the Drawing or Specification page to help expedite the response.
- Last day for questions: seven (7) days prior to bid opening.
- Only questions answered by formal written addenda will be binding.
- Must submit emailed or mailed acknowledgement of all addenda.

5. Bid Security

- Certified Check, Bank Money Order, or Bond in an amount equal to not less than five percent (5%) of the Bid.
- Section 00 20 00 – Instruction to Bidders (Article 10)

6. Contract Time

- Substantial Completion – 262 days
- Final Completion – 292 days
- Reference Section 00 52 00 – Agreement, for Liquidated Damage information

Hazen

7. **Bid Form**

- Submit Section 00 40 00 – Bid Form and all other required documents per Article 9. Do not strike through any wording of the form. Do not remove any pages from the bound documents.
- Total Single Prime Base Bid Price

8. **Bids to Remain Open**

- 60 days per Section 00 40 00 – Bid Form

9. **Award of the Contract**

- Refer to Section 00 20 00 – Instruction to Bidders.
- Anticipate NTP approximately August-September 2022.

10. **Permits**

- Shall be obtained by and paid for by the Contractor.

11. **Project Funding**

- The City of Havelock will fund this project through American Rescue Plan Act (ARPA).
- Bidder shall meet requirements of Section 00 53 00

12. **Sales Tax**

- See Section 00 20 00 – Instructions to Bidders.
- The Bidder shall include North Carolina Sales and Use Tax in the Bid. See Section 00 73 00 – Supplementary Conditions, for more details.

13. **01 14 00 – Coordination with Owner's Operations**

- Reference this Section for specific project constraints and notification requirements for shutdowns.

14. **Examination of Site**

- May inspect the site today
- Additional site visits can be made by contacting bids@havelocknc.us
 - Requests shall be made at least 72-hours in advance of proposed Site visit and at least five (5) days prior to opening of Bids

ATTENDEE SIGN IN
Pre-Bid Meeting

City of Havelock WWTP Influent Pump Station 1 Modifications
City of Havelock, NC
Tuesday May 31, 2022
1:30 PM

304 Jackson Dr, Havelock, NC 28532

NAME	COMPANY	EMAIL
BUK DAY	CITY OF HAVELOCK PUB UTIL DIR.	rday@havelock.nc.us
JASON WHITF	SOUTHEAST FRESHWATER	JASON@SEI-SERVICES.COM
Kyle Jefferys	A.C. Schultes of Caroling	central@acschultes.com kyle@acschultes.com
Nathan Howard	turner murphy company	nmurphy@turnermurphy.com
FREDDIE HUDSON	GODWIN PUMPS (XYLEM)	frederick.hudson@xylem.com
Devin Adams	City of Havelock	Dadams@havelocknc.us
FARIS MATAR	HAZEN	fmatar@hazenandzinger.com
TYLER SUTTON	TA LIVING CO.	TSUTTON@TALIVING.COM
ben Pollock	Laughlin-Sutton	benpollock@laughlin-sutton.com