

33rd STREET NW AREA WATER MAIN REPLACEMENT Tag 575

The City of Canton

Addendum 2

City of Canton, Ohio

Purchasing Department

218 Cleveland Ave. SW, 4th floor

Canton, Ohio 44702

33rd STREET NW AREA WATER MAIN REPLACEMENT Tag 575

Item/Project

Water Department

Responsible Department

April 4, 2019 at 2:00 PM local time

Bids Due On or Before

Bid Proposal Submitted By:

Company Name

Street Address

City

State

Zip

Contact Person

Phone No.

Email Address

1. Are waterline fittings to be imported or domestic?

Domestic

2. Do the T-bolts and Nuts for the Megalug Kits need to be Standard Cor-Ten or Stainless Steel?

Standard Cor-Ten is acceptable.

End of Addendum