

ADDENDUM NO. 1

DATE: March 23, 2018
TO: All Bidders
FROM: Boyce H. Evans, Purchasing Agent
SUBJECT: Addendum No. 1 – KAT Summit Hill Transit Stop Project
BIDS TO BE OPENED: April 4, 2018, at 11:00 a.m. (Eastern)

This addendum is being published to make changes to the Contract Documents and specifications as well as respond to questions that the City has received from potential bidders. The City's responses hereby become a part of the Contract Documents and modify the original specifications as noted below.

Changes to the Contract Documents & Specifications:

1. The project construction time is being extended from 90 to 120 days. The language on page BD-7 of the project specifications shall state "Bidder hereby agrees to commence work under this contract on or before a date to be specified in the Notice to Proceed and to fully complete the Project within one hundred twenty (120) calendar days thereafter."
2. The Contractor shall install the pedestrian handrail on top of the retaining wall by coring into said retaining wall. The handrail shall be 42" tall as detailed on Plan Sheet #5. The plate detail on Plan Sheet #5 shall not be used. The price of all equipment and labor necessary to perform this installation shall be included in the unit price of Pay Item 64.40 Pedestrian Handrail and be paid for by the linear foot.

Clarifications to the Contract Documents & Specifications:

Questions Received:

Question #1: Will special bolts be needed to install the light poles on this project similar to what were used on the 700 Block Gay Street Project?

Response #1: No, there is no need for special anchor bolts. The Contractor shall install the poles to the foundations as detailed on Plan Sheet #0.01 and Sheet #2.00.

END OF ADDENDUM NO. 1