



PERALTA COMMUNITY COLLEGE DISTRICT

MERRITT COLLEGE CHILD DEVELOPMENT CENTER (CDC) BUILDING

ADDENDA

BID NO. 21-22/08

Peralta Community College District

333 East 8th Street Oakland, CA 94606

May 13, 2022

ADDENDUM No. 5

This addendum supersedes items of the original bid documents wherein it is inconsistent with it. All other conditions remain unchanged. The following changes, modifications, corrections, additions, or clarifications shall apply to the contract documents and shall be made a part of and subject to all of the requirements thereof as if originally specified or shown. It is the responsibility of the proposer to review the list of attachments to ensure that the addendum is full and complete. This Addendum modifies the original Bid Documents for the above project.

Acknowledge receipt of this addendum in the space provided on Acknowledgement and Signature Form. Failure to do so may subject proposer to disqualification.

Revisions/Questions to Bid documents:

1. Clarification for Section 07 Specification:

Increment 2, Section 07 4213.23, 2.02 A.2:

The metal composite material wall panels should be a "DRY" system, not wet.
The dry system is shown on architectural details and spec should reflect a dry system.

2. Clarifications on the Increment 02 landscaping plans and specs are included here.

(End of Document)