



Terry McKee, IT & Procurement Director

901 Broadway N. ♦ Knoxville, TN 37917-6699

865.403.1133 ♦ Fax 865.594.8858

purchasinginfo@kcdc.org

www.kcdc.org

### Addendum

<b>SOLICITATION NAME</b>	Renovations at Passport Homes (PHA Units) C17022	<b>ADDENDUM NUMBER</b>	5	<b>DATE</b>	11-02-16
--------------------------	---	------------------------	---	-------------	----------

This addendum answers questions raised about this solicitation. To aid in readability, the questions are in black, the answers are in **bolded blue**, and the answers follow immediately below.

Q1	Question on, I. Bathrooms Exhaust Vents -Replace 4" vent pipe with Deflect-O Double-Ply Flexible Aluminum Duct-Is the replace, just the hook-up, or the entire line out to soffit or roof?
	<b>It is the entire line out to the soffit or roof.</b>

End of Addendum

