

CLAYTON COUNTY WATER AUTHORITY

Request for Bids

Liquid Oxygen and Tank Rental for Shamrock and Blalock Reservoirs

Bid Number: 2018-WP-08

Bid Opening: Wednesday, May 2, 2018 at 3:00 p.m. (local time)

Non-Mandatory Pre-Bid Meeting: Thursday, April 19, 2018 at 3:00 p.m. (local time)

A D D E N D U M # 1

*Acknowledgment of receipt of this addendum **MUST BE SIGNED AND INCLUDED IN YOUR RESPONSE TO THE RFB.***

REVISION:

1. Under Division 4 Section 3: General Requirements of the RFB package, revise the first paragraph under item 3.2 ("Performance Requirements") to read as follows:

3.2 Performance Requirements

1. System shall provide gaseous oxygen that has been fully vaporized from liquid oxygen. **The liquid oxygen supplied shall be comprised of at least 99.5% pure oxygen.**

2. The following drawings are attached for bidder's reference:

- **FIGURE 1 – LOX SITE GRADING AND STAKING PLAN**
- **FIGURE 2 – LOX AND CHEMICAL STORAGE AND FEED PLAN AND SECTIONS**
- **FIGURE 3 – LOX AND CHEMICAL STORAGE AND FEED PLAN AND SECTIONS**
- **FIGURE 4 – LOX AND CHEMICAL STORAGE AND FEED ISOMETRIC**
- **FIGURE 5 – LOX AND CHEMICAL STORAGE AND FEED POWER AND LIGHTING PLAN**

These figures are for reference only and are intended to show where the LOX tank and associated equipment will be located.

SIGNATURE

COMPANY NAME

DATE