



June 13th, 2017

RE: ADDENDUM #1, FACADE RESTORATION IMPROVEMENTS TO 711-713 NORTH MAIN STREET FOR THE CITY OF COLUMBIA, COLUMBIA, TENNESSEE, FILE NO: 2015021

ATTENTION ALL APPLICABLE BIDDERS:

Please amend your contract documents and specifications dated May 26th, 2017 (or as specified otherwise herein) as addendum #1. Below are listed the following corrections/changes required to be made:

DRAWING AMENDMENTS/CHANGES

1. Drawing A10, dated May 10th, 2016, is amended in the following particulars:
 - a. Reference Revision #1, Drawing A10. Clarification: After working with the Grant facilitators, The Tennessee Historical Commission, we had to modify the proposed door replacements to the design depicted. Additionally, we have included a door hardware supplement sheet which is a companion document to the door detailing. As mentioned in the pre-bid meeting, the doors will need to be wired for power although the contractor will not be responsible for hooking up power on either door unit for this scope of work. All junction box rough-ins for the paddle actuators and junction box for wiring the main power to respective door will be part of the work scope. Wires will be pulled and capped. The Contractor and Architect will coordinate these junction box locations in the field.

ITEMS OF GENERAL CLARIFICATION

1. Please be advised that demolished items become the property of the Owner. Please coordinate the removal of all disposed items with the Architect prior to removal/disposal.

END OF ADDENDUM #1

If you have any additional comments or concerns, do not hesitate to call our office.

Sincerely,

George Nuber, Architect

ATTACHMENTS

Architectural Drawing A10
Door Hardware companion sheet

