

Procurement & Property Division



Request for Proposal **West Main Trail Project** **Addendum III** **Questions and Answers**

- 1.) Is the mill a uniform 2" across the entire road?
- 2.) Can milled areas be left open to traffic?
- 3.) Is the stained concrete pavement quantity correct as SF and not SY?

Please review sheet No. 3A for "Typical Sections"

Traffic can be allowed for any milling that is 2" or less, but please review the sheet above for a definitive answer. There is language dealing with variable mill & overlay, however note 4 on the page offers additional insight.