



**CITY OF DUBLIN  
ADDENDUM #1  
BID #23-03-003**

DATE: March 28, 2023  
TO: Metal Building Contractors  
FROM: Kris Harden, Purchasing Director  
SUBJECT: Changes and Additions to the Bid

As a result of the bid being posted, some questions have arisen that need clarification. Also, please take note of the new bid opening date. The following is a list of the clarifications, changes and additions to this bid. Should you have any questions, please email me at [hardenk@dublinga.org](mailto:hardenk@dublinga.org).

Be sure to submit this signed form with your proposal to acknowledge your receipt of the addendum along with other required forms in the bid package.

**CHANGES/CLARIFICATIONS/ADDITIONS:**

- 1. New bid due date: **Tuesday, April 11, 2023, at 2:00 PM****
- 2. Pre-engineered building is acceptable as long as the steel gauge is disclosed to make sure it meets the minimum requirement.**
- 3. The contractor is responsible for getting an electrician to make the final tie in. A Georgia Power meter base will be required for this installation.**
- 4. Minimal site work is needed**
- 5. 120-volt circuits; quad duplex receptacles are required – 16 each, 4 on each wall**
- 6. A structural drawing of the concrete must be included in price**
- 7. 14' of clearance for interior working space inside the building**
- 8. Roll up doors need to be on the gable side of the building**
- 9. 240 CFMs are sufficient for this building size**

**I have read the above changes and additions to the original bid and will submit my bid accordingly.**

**Bidder:** \_\_\_\_\_

\_\_\_\_\_  
**Signature**

\_\_\_\_\_  
**Date**