

October 6, 2022

ADDENDUM NO. 1

**TO THE
CONTRACT DOCUMENTS FOR
LOWER BLOOMERY SWAMP SEWER IMPROVEMENTS
CITY OF WILSON, NORTH CAROLINA**

Bid Date: **October 12, 2022 – 11:00 A.M.**

From: **Green Engineering, P.L.L.C.
Consulting Engineers
Wilson, North Carolina**

NOTICE TO BIDDERS:

This Addendum is issued prior to the receipt of bids for the above project and **must be** acknowledged on Page 1 of 8 of the BID FORM where indicated.

The CONTRACT DOCUMENTS for this work are modified as follows:

CONTRACT DOCUMENTS:

Bid Form: The Bid Form has been modified to remove the “Alternate” from Part B resulting in a two (2) Part Bid Form with a Total Bid for both Parts being the basis of award. The Revised Bid Form is attached to this Addendum No. 1.

SPECIFICATIONS

Pre-Approved Material/Product List: The attached Pre-Approved Material/Product List is attached to this Addendum No. 1 and is hereby being made part of the Contract Specifications.

PLANS

Plan Sheet 20 of 22, (Index, General Notes and Abbreviations), The Construction Notes have been revised now that the project scope is to install the proposed sewer improvements in the same location as the existing gravity sewer instead of a parallel installation. A revised plan sheet is attached to this Addendum.

GENERAL COMMENTS

The following notes were compiled during the Pre-Bid Meeting:

1. Please note in the bid that funds are currently available for Part A with federal money. Part B is being bid also due to the intention of awarding the entire contract as a whole based on the continuation of the project and the lowest responsive responsible bidder for the total of both Parts A & B.
2. There are bypass pumps currently on this outfall line that are the City's. The City is expecting the contractor to provide their own bypass pumping for this project so please price accordingly.
3. Please note that this project is in the flood plain and runs parallel to Contentnea Creek. Planning is extremely important for this project due to potential flooding or access issues.
4. Time of Completion is 360 calendar days as stated under Article 4 – Contract Times of the RFP document. The Engineering Firm and City will work with awarded contractor on specifics if there is a justifiable outlier.
5. Is there a preference as to what part will need to be started first? The Contractor will need to start with part A first, due to funding and will need to plan accordingly with their bid.
6. Will a water source be provided by the City? No, the contractor will be responsible for providing any water necessary.
7. Please note any dewatering will need to be put back into the sewer system/downstream manhole, not back into Contentnea Creek or the environment. This project is adjacent to a water source for Wilson and other downstream communities.
8. This project has federal funds involved, please pay close attention to the Federal Provisions and ensure that you can comply with all provisions.
9. If there is a need to walk or ride the site please contact Green Engineering.
10. Questions for this project are due to the Engineer by 5:00 pm October 4, 2022.
11. Bid opening is 11:00 am Wednesday, October 12, 2022 at the Operations Center Conference Room.

END OF ADDENDUM NO. 1