



Terry McKee, IS & Procurement Director
 901 Broadway, N.E. • Knoxville, TN 37917-6699
 865.403.1133 • Fax 865.594.8858
 purchasinginfo@kcdc.org
 www.kcdc.org

Addendum

SOLICITATION NAME	HVAC Services at North Ridge Crossing C16005	ADDENDUM NUMBER	2	DATE	07-31-15
--------------------------	--	------------------------	---	-------------	----------

KCDC is using this addendum to answer the questions raised about this solicitation. To aid in readability, the questions are in black, the answers are in bold, and the answers follow immediately below.

Q1	Does RRP certification apply?
	No.
Q2	How many feet of PVC is needed?
	Approximately 80 total feet per apartment.
Q3	Who is responsible for recording the serial numbers, apartment number and address?
	The vendor is responsible for accurately performing this work.
Q4	How much resident notice is required?
	HUD requires 48-hour advance notice to residents before work occurs.