

“City of Havelock  
Public Services Storage Building”  
Addendum 2  
June 26, 2020

Questions Received

1. Bay spacing 12 feet. This would mean you would have twelve 12' bays with one 6' bay. I'm sure this is incorrect. I could understand Six 25' bays; where the two end bays would be somewhere around 24' frame to frame. Please see if I'm correct. Maybe they are wanting the ability to have two 12' parking areas per bay.

Six 25' Bays with the two end bays being around 24' frame to frame.

2. I sure with 140 MPH wind loading the standing seam roof will be required. However, the insulation of R-30 is typically for a conditioned space per code and is typically a liner system. This being a shelter we would typically use R-10 3" or we can use R-13 4" Skrim type insulation; this would keep it cooler under the shelter area. Please make sure they are wanting R-30??

R-30.

3. In above item 12 you stated R-30 insulation and in this you are saying 6". Will insulation be 6" R-19 standard backing or R-30??

R-30.

4. What R-value for wall insulation in Alternate #1? R-13 or same as item 13 R-19 6"?

R-19 6".

5. Same as item numbers 12, 13? R-30 or R-19?

R-19.

6. If manufacturers standard primer is Grey is this ok?

Yes.