



Jackson County Board of Commissioners

67 Athens Street
Jefferson, Georgia 30549
Phone: (706) 367-6309
Fax: (706) 708-2505
Email: myarbrough@jacksoncountygov.com

Date: August 22, 2022

To: HVAC Contractors

From: Myrna Yarbrough, Purchasing Manager

RE: Addendum 3 to Jackson County ITB 220026, Replace Rooftop HVAC Unit at the Jail, Jackson County GA.

1. Please see attached answers to questions and clarify. All other information remains the same.
2. All other terms and conditions in ITB 220026 remain unchanged.
3. Any inquiries concerning Addendum 3 should be made to Myrna Yarbrough, Purchasing Manager, (706) 367-6309 or via email at myarbrough@jacksoncountygov.com
4. Jackson County reserves the right to reject any and all proposals, to waive any technicalities or irregularities and to award the offer based upon the most responsive, responsible submission.
5. Bidders must acknowledge receipt of addenda, by either signing and attaching this copy, or by writing "Acknowledge Addenda #3" at bottom of the proposal.

1. What options are required for the replacement Carrier unit? The only unit is a Carrier Model 48P7D0706 rooftop unit.
2. Would it be possible to release the drawing of the old unit and replacement unit? We do not have cut sheets on either unit. It should be available from Carrier.
3. What is an acceptable timeframe for downtime for the unit replacement? Should be less than 3 days.
4. Is it possible to schedule a second site visit? No

Contractor is responsible for removal and disposal of old equipment and materials.